Exhibit A – Location of the System

LOCATION OF AC COMBINER, ENERGY STORAGE, TRANSFORMER, PV AND STORAGE METERS

AC RUN ~800'

PROPOSED POCC AT
12kV, 1200A
STORAGE SITE REFERENCE METER
Switchgear located outside
SAID: 388716483

FENCING REQUIRED, TYP.

20' PERIMETER ACCESS
ROADS REQUIRED